



GOVERNMENT OF TAMIL NADU

DIRECTORATE OF PUBLIC HEALTH AND PREVENTIVE MEDICINE

பொது சுகாதாரம் மற்றும் நோய்த் தடுப்பு மருந்துத்துறை

SELF DECLARED SANITATION CERTIFICATE

(Issued under G.O.(Ms)No. 276 of Health and Family Welfare (AB2) Department dated

23.09.2024 on the basis of affidavit by the applicant)

Certificate Number : TN00125DGL04218

Issued Date : 30-07-2025

Organization Type : Educational Institutions

Expiry Date : 29-07-2026

Name of the Organization : PANNAI PUBLIC SENIOR SECONDARY
SCHOOL CBSE

Address : S NO 399/3, 400/3A,1B,1E, 401/2B PART, 402/1,2,3,4,
403/3,4,6A,6B,6C AROCKIASAMY NAGAR TRICHY ROAD
MULLIPADI VILLAGE PANCHAYAT

I, LEENA SHREE owner/manager of the PANNAI PUBLIC SENIOR SECONDARY SCHOOL CBSE functioning as Educational Institutions located at Mullipadi in Dindigul district hereby declare that

- This Self-Declared Sanitation certificate is valid from 30-07-2025 to 29-07-2026 and will be renewed every year prior to the expiry of the current certificate with updated information.
- Our premises can accommodate 607 people/pupils and has 42 urinals and 27 toilets which is proportionate to the number of users as per government norms.
- 10 Sanitation workers are deployed to clean the entire premises including Toilets, Common Area Spaces, etc., at regular intervals and proper record is maintained.
- The waste generated on our premises is properly processed and disposed of as per Solid Waste management Rules, 2016.
- There is no potential mosquito breeding area on the premises.
- The premises have adequate drinking water fountains on each floor of the premises.
- The self-declared certificate is displayed prominently on the premises along with the protocol

The Government reserves the right to inspect at any point of time and cause for rectification or cancel or suspend the certificate and take legal action if any conditions are violated.

Signature of the Owner/Manager



(அ) TN00125DGL04218 என்ற தனிப்பட்ட சான்றிதழ் எண்ணை

<https://www.tnesevai.tn.gov.in/edistrict/CheckStatus/Certificate/> ல் உள்ளீடு செய்து சரிபார்க்கவும்.

(அல்லது)

(ஆ) கைப்பேசியில் பாரகொடு படிப்பான் மூலம் இணையதளத்தில் சரிபார்க்கவும்.

Genuineness of the certificate can be verified by.

(a)Keying in the unique certificate number TN00125DGL04218 in the URL

<https://www.tnesevai.tn.gov.in/edistrict/CheckStatus/Certificate/>

(or)

(b)Reading the 2D barcode with mobile barcode reader and verify through online.



TEST WATER BEFORE TASTE
TAMILNADU WATER SUPPLY AND DRAINAGE BOARD
DISTRICT WATER TESTING LABORATORY,
5/860, ANBU ILLAM, TRICHY ROAD, N.G.O.COLONY,
DINDIGUL - 5. Phone No. : 0451-2410188

From
J.Amala Lourdu Mary B.Sc(spl),B.Ed.,
 Junior Water Analyst A/C, TWAD Board,
 District Water Testing Laboratory,
 Dindigul.

To
M/S Pannai Public School (CBSE),
 Arockiasamy Nagar,
 Mullipadi (P.O),
 Dindigul.

Lr.No: 33355 & 33356 /JWA/DGL / 2014 / Dated. 09.04.14.

Sir, Sub:Examination of water sample - Report furnished - Reg.
 Ref: 1) Your Lr No Nil /DGL/Dt. 04.04.14,
 2) Our Invoice No.430/Dt. 04.04.14 for Rs.700/=

The results of analysis for the given water samples are enclosed.

Sample No			33355
Date of Collection			04.04.14
Collected by			I.Paul Raj, Principal
Scheme /Purpose			Private
Location of Sampling			Correspondent room back side
Panchayat/Habitation			Mullipadi
Union			Dindigul
Source			Bore well / Power Pump
I.PHYSICAL EXAMINATION	BIS Desirable limit	BIS Permissible limit	
1. Appearance	Clear
2. Colour (pt.co-scale)	5	25	Colourless
3. Odour	unobjectionable		None
4. Turbidity NT units	5	10	1
5. Total dissolved solids mg/l 500		2000	50
6. Electrical conductivity micS/cm		...	73
II.CHEMICAL EXAMINATION			
7. pH	6.5-8.5	6.5-8.5	6.14
8. Alkalinity-Ph as CaCO ₃	0
9. Alkalinity Total as CaCO ₃	200	600	4
10. Total Hardness as CaCO ₃	200	600	5
11. Calcium as Ca	75	200	1
12. Magnesium as Mg	30	100	0
13. Sodium as Na	200	200	12
14. Potassium as K			4
15. Iron Total as Fe	0.3	0.3	0.05
16. Manganese Mn	0.1	0.3	0.00
17. Free Ammonia as NH ₃	0.5	1.0	0.04
18. Nitrite as NO ₂	0.5	1.0	0.00
19. Nitrate as NO ₃	45	45	1
20. Chloride as Cl	250	1000	21
21. Fluoride as F	1.0	1.5	0.2
22. Sulphate as SO ₄	200	400	2
23. Phosphate as PO ₄	0.5	1.0	0.05
24. Tidy's Test 4hrs as O ₂			0.16
25. Residual Chlorine		0.2	0.00
III.BACTERIOLOGICAL EXAMINATION		Maximum	Lab No: 33356
26. Fecal Coliform /100ml		0/100ml	30

REPORT: 33355 : The given water sample is chemically not potable due to the acidic pH.

The pH must be maintained in the Optimum range of 7 to 8.5.

33356 : The given water sample is bacteriologically contaminated due to the presence of fecal coliforms.

for P. Karuppusamy
 Junior Water Analyst A/C ,
 TWAD Board, DWT Lab,DGL.